



GENERAL NOTES:

1. At locations where sidewalk is subjected to wheel traffic and/or constructed across access drive entrances, the P.C.C. Sidewalk Section shall be thickened to 6" across the width of the driveway.
2. Placing, finishing and curing of P.C.C. Sidewalk shall meet the requirements of Sections 424 & 1020 of the Standard Specifications for Road and Bridge Construction. Use Class SI IDOT approved mix design approved by the Engineer.
3. Slab or panel contraction (control) joints shall be as follows:
 - For 4' Sidewalk width = 5' O.C. Joint Spacing
 - 5' Sidewalk width = 5' O.C. Joint Spacing
 - 6' Sidewalk width = 6' O.C. Joint Spacing
 - 8' Sidewalk width = 8' O.C. Joint Spacing
4. Transverse expansion joints shall consist of preformed joint filler of thickness as follows:
 - 1/2" between sidewalk and structures, standards, poles
 - 3/4" at sidewalk intervals of not more than 50 feet & abutting concrete curbing or pavement.
5. If excavation or undercutting of subgrade has been made deeper than necessary, the base shall be brought to proper grade by the addition of well compacted bedding material without any extra compensation due the Contractor.

TYPICAL SECTION - P.C.C. SIDEWALK

Issued by: DLZ 10/11/00		
By	Revised	Date
SD		1-4-06
MJ		6-23-14

**VILLAGE OF GURNEE
ENGINEERING DIVISION**

Approved by:	
SD	1/4/06
SD	6/23/14