



\* All Service Saddles Shall Be Double Strap; Bronze Nylon Coated or Stainless Steel Conforming to Village of Gurnee Standards

## WATER SERVICE INSTALLATION

Issued by: DLZ 10/11/00		
By	Revised	Date
SD		1/4/06
MAD		7/28/11
MJ		6/25/14

**VILLAGE OF GURNEE  
ENGINEERING DIVISION**

Approved by:
SD 1/4/06
SD 7/29/11
SD 6/25/14