

**ADDENDUM NO. 1**

DATE: January 18, 2021

PROJECT: **2021 Bridge Rehabilitation**

OWNER: VILLAGE OF GURNEE

TO: PROSPECTIVE BIDDERS

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents approved for bid, with the amendments as noted below.

This Addendum consists of one (1) page. This Addendum contains the following revisions:

Clarifications

1. On structure # 049-6162 on Cunningham Ct:
  - a. A roller screed can be used instead of a bidwell.
  - b. In order to maintain access for residents and emergency vehicles, the contractor must keep one side of the road open at all times. Contractor shall use barricades, drums, jersey wall or any combination thereof to protect the work and public.

**CHANGES TO THE CONTRACT DOCUMENTS AND SPECIFICATIONS**

Signed:  \_\_\_\_\_

Village of Gurnee  
Nicholas Leach  
Project Engineer

Please acknowledge receipt of this Addendum by signing below and faxing or emailing a copy of the Addendum to the Village of Gurnee, Engineering Department at (847)-623-9475 or [engineering@village.gurnee.il.us](mailto:engineering@village.gurnee.il.us). Failure to do may disqualify the Bidder.

\_\_\_\_\_  
Firm

\_\_\_\_\_  
By

\_\_\_\_\_  
Name

\_\_\_\_\_  
Title